



PERFORMANCE TESTING IN ACCORDANCE WITH
AAMA/WDMA/CSA 101/I.S.2/A440-11 (NAFS 2011), CSA A440S1-09 & CSA A440S1-17
AAMA/WDMA/CSA 101/I.S.2/A440-17 (NAFS 2017) & CSA A440S1:19

PRODUCT MANUFACTURER
TORBAU SCHWABEN GmbH Enzianstraße 14, 88436 Eberhardzell, Germany +49 7355 93100

REPORT AI-05482-A1

TEST REPORT SUMMARY	
Product type Product series/model	Side-Hinged Door AquaLOCK
Primary designator	Class CW – PG100: Size tested 1000 x 2100 mm (~40 x 83 in) - Type SHD
Optional secondary designator	Positive Design pressure (DP) = 4800 Pa (~100.25 psf) Negative design pressure (DP) = -4800 Pa (~-100.25 psf) Water penetration resistance test pressure = 720 Pa (~15.04 psf) Canadian air infiltration/ exfiltration level = A3 Level (NAFS-11) / Not applicable (NAFS-17)

See UL Laboratory Canada Inc. complete report AI-05482-A1 for test specimen description and detailed test results

Test laboratory location	UL Laboratory Canada Inc. (Varennes laboratory)		
Test completion date	2019-11-12	Number of pages	7 pages & 1 appendix
Report date	2021-12-13	Revision date	-

Prepared by:

Digitally Signed by:
Eric Perron, Tech.
Fenestration Testing Department
UL Laboratory Canada Inc.

Approved by:

Digitally Signed by:
Jason Michaud
Assistant Manager, Fenestration Testing Department
UL Laboratory Canada Inc.

LABORATORY, FIELD TESTING AND ADVISORY SERVICES FOR THE BUILDING ENVELOPE

TORONTO
7 Underwriters Road
Toronto
ON M1R 3A9
Canada
T: +1.866.937.3852
E: BuildingEnvelope@ul.com

MONTREAL
1320 Lionel-Boulet Blvd
Varennes
QC J3X 1P7
Canada
T: +1.855.353.2532
E: BuildingEnvelope@ul.com

TELFORD
Halesfield 2
Telford
TF7 4QH
United Kingdom
T: +44.1952.586.580
E: BuildingEnvelopeEurope@ul.com

W: ul.com/buildingenvelope