

Inspection Certificate

AquaLOCK Flood-Protection Gate



width 1,86 m

impundment:	102 cm
inspection duration:	24 hours
measured leakage volume:	0,69 litre

The inspected flood-protection gate is certified to be waterproof for the application outside of buildings.

Biberach, March 19th 2021

A handwritten signature in blue ink, appearing to read 'Gerhard Haimerl', written in a cursive style.

(Prof. Dr.-Ing. Gerhard Haimerl)