



TESTING COMPLETED IN ACCORDANCE WITH ANSI/DASMA 105-2020

Submitted to:

Torbau Schwaben GmbH
Enzianstraße 14, 88436
Eberhardzell
Deutschland

Report No.: AT-00858

Product Type:	Garage Door
Product Series/Model:	AquaLock Garage Door
Overall Test Specimen Dimensions:	3048mm (W) x 3048mm (H) (120in x 120in)
Test Specimen Thermal Transmittance (U):	2.91 W/(m ² °K), (0.51 BTU/(hr ft ² °F))
Air Infiltration Rate @ 75 Pa (1.57 psf):	6.01 L/s-m ² (1.20 CFM/ft ²)
Report Date:	2021/12/21
Revision Date:	N/A
Number of Pages:	6

Note: Reference must be made to UL Laboratory Canada Inc.. complete report for test specimen description and detailed test results.

Prepared by :

Frédéric Currier

Thermal Evaluation Department
UL Laboratory Canada Inc.

Approved by :

Marilyne Thibault B. Sc.

Person In Responsible Charge
UL Laboratory Canada Inc.

LABORATORY, FIELD TESTING AND ADVISORY SERVICES FOR THE BUILDING ENVELOPE

TORONTO
7 Underwriters Road
Toronto
ON M1R 3A9
Canada
T: +1.866.937.3852
E: BuildingEnvelope@ul.com

MONTREAL
1320 Lionel-Boulet Blvd
Varenes
QC J3X 1P7
Canada
T: +1.855.353.2532
E: BuildingEnvelope@ul.com

TELFORD
Halesfield 2
Telford
TF7 4QH
United Kingdom
T: +44.1952.586.580
E: BuildingEnvelopeEurope@ul.com

W: ul.com/buildingenvelope